

Regional Water Testing Laboratory
Water Supply and sanitation, Amritsar

ID No. RWTLASR/501

Dated 14/07/2021

TEST REPORT
Chemical Testing

Sr. No	Group	Sample Tested in Group (√)
1.	Residues in Water	
2.	Water	

Sample Registration No. : RWTLASR/501
Sample code given by customer: Not Applicable

Issued to: - The Principal
Sant Sar Public Sen. Sec. School, Butala, Amritsar

SAMPLE PARTICULARS

Ref. Letter No. : sps/B/WS/256/21 DT 23.06.2021
Date of Receipt : 25/06/2021
Sample code given by customer : NA
Name / Nature of sample : water
Condition of the sample : Un-Sealed Sample
Qty / Pkg : 1000 ml Glass Bottle
Sampling Method : Sample not drawn by RWTLASR
Test Start Date : 28/ 06/2021
Test Completion Date : 28/06/2021

Note:


Quality Manager/ Sr. Chemist
Senior Chemist
Authorised Signatory
For Regional Water Testing Laboratory,
Amritsar


- ☞ The enclosed results pertain only to the sample tested.
- ☞ The report shall not be used for advertising or any legal purpose without written permission from the Head, DWSS.
- ☞ This report cannot be re-produced, except when in full, without the written permission from the Head, DWSS.
- ☞ The sample shall be destroyed after one month from the date of issue of the report.

Regional Water Testing Laboratory, Amritsar

Date : 14/07/2021

S No	Registration No	District	Block	Name of Place/Village	Sample Receipt Date	Date of Collection	Source	Depth	pH	TDS (mg/l)	Total Alkalinity (mg/l)	Total Hardness (mg/l)	Turbidity	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Colour	Taste	Odour	
As per IS 3025-2017 : Requirement (Acceptable limit - Permissible limit) mg/L																				
1	RWTLASR/501	Air	NA	Sant Sar Public Sen. Sec. School, Butala, Air	25-06-2021		Not Mention	SP	300 ft	7	280	340	340	0.5	56.1	24.3	1.35	Agreeable	Agreeable	0

End of Report


 Quality Manager/Sr. Chemist
 Senior Lines
 RWTL Amritsar
 Authorised Signatory
 For Regional Water Testing Laboratory,
 Amritsar